



### OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on August 2, 2017.

**Royal Coatings, Inc.**  
**2705 Concord Road**  
**Belle Chasse, LA 70037**  
**800-815-8811**  
**504-392-8811**

**Facility: Belle Chasse, LA**

Trade Designation	Protective (Barrier) Materials		Water Contact Temp	Water Contact Material
	Water Contact Size Restriction			
<b>Coatings - Fittings</b> [1] [2] [G]				
Royal PC-12	>= 3"		CLD 23	ASPH
<b>Coatings - Pipe</b> [1] [2] [G]				
Royal PC-12	>= 3"		CLD 23	ASPH

- [1] Number of Coats: 1-3  
Maximum field use dry film thickness (in mils): 5  
Maximum thinner: 5% water by volume  
Recoat cure time and temperature: 1 hour at 77°F  
Final cure time and temperature: 48 hours at 77°F  
Special comments: 53% solids
- [2] Only products bearing the NSF Mark on the product, product packaging, and/or documentation shipped with the product are Certified.
- [G] Product is Certified to NSF/ANSI 372 and conforms with the lead content requirements for "lead free" plumbing as defined by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.