



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of
NSF/ANSI Standard 372 - Drinking Water System Components - Lead Content

This is the Official Listing recorded on August 2, 2017.

Royal Coatings, Inc.
2705 Concord Road
Belle Chasse, LA 70037
800-815-8811
504-392-8811

Facility: Belle Chasse, LA

Coatings - Fittings [1] [2] [LL]

Royal PC-12

Coatings - Pipe [1] [2] [LL]

Royal PC-12

[1] Number of Coats: 1-3
Maximum field use dry film thickness (in mils): 5
Maximum thinner: 5% water by volume
Recoat cure time and temperature: 1 hour at 77°F
Final cure time and temperature: 48 hours at 77°F
Special comments: 53% solids

[2] Only products bearing the NSF Mark on the product, product packaging, and/or documentation shipped with the product are Certified.

[LL] Product conforms with lead content requirements for "lead free" plumbing as defined by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.