

Certificate of Compliance

Certificate Number 100606-MH18325
Report Reference MH18325, February 16, 2006
Issue Date 2006 October 6

Page 1 of 1



**Underwriters
Laboratories Inc.®**

Issued to: **Royal Chemical Corp**

2705 Concord Rd
Belle Chasse, LA 70037

*This is to certify that
representative samples of*

Royal PC

Maximum Use Temperature,
°C
23

Maximum Product Surface Area/
Water Volume Application, cm²/L
525 cm²/L


*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: ANSI/NSF Standard 61 Drinking Water System Components

Additional Information: Factory Locations: Belle Chase, LA and Port Allen, LA

"For Pipes and Fittings, 3" and larger. Dry Film Thickness = 3 mils.
Minimum Cure Time = 7 days".

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product

Issued by: *Rachel Balmer*
Rachel Balmer
Underwriters Laboratories Inc.

Reviewed by: *Thomas Bowman*
Thomas Bowman
Underwriters Laboratories Inc.