

# Certificate of Compliance

Certificate Number 080724  
Report Reference MH18325, 2001-05-18  
Issue Date 2008 July 24

Page 1 of 1



*Issued to:* Royal Chemical Corp

2705 Concord Rd  
Belle Chasse, LA 70037  
United States

*This is to certify that  
representative samples of*

**EASY PRIME and EASY FLEX**


Epoxy Coating  
Number of Coats: 2  
Sequence of Coats: EASY PRIME primer followed by EASY FLEX finish coat

*Have been investigated by Underwriters Laboratories Inc.® in  
accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:* NSF/ANSI 61-2007a, Drinking Water System Components - Health Effects

*Additional Information:* For tanks  $\geq 200$  gallons, pipes  $\geq 24$ ", and pipe fittings,  $\geq 2$ ". Maximum Surface Area to Volume ratio = 67.7 sq cm/L.  
Maximum Field Use Dry Film Thickness (in mils): 3 per coat.  
Re-coat/Cure Time: 8-12 hours/36 hours.

**Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.**

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

**Look for the UL Classification Mark on the product**

Issued by: *Rachel Balmer*

Reviewed by: *Tom Bowman*

**Rachel Balmer, Sr. Project Engineer**

**Tom Bowman, Staff Engineer**

**Underwriters Laboratories Inc.**

**Underwriters Laboratories Inc.**

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL. For questions in The United States of America you may call 1-877-UL-HELPS.